



APPENDIX - VII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.

No. Dum/101/2019

Date: \_\_\_\_\_

It is certified that an inspection team headed by Mohammad -  
-Ejazuddin Panchayath Secretary (Name of Officers  
with designation) from Panchayath Raj Department (Name of  
Department Office) inspected the T.T.W. E.M.R.S (Girls) -  
G.P: Dumala Mondli Yellareddy P.M. Rajanna Sircilla (Name & Address of  
the School) on \_\_\_\_\_ and found that the Sanitation Condition -  
and pattern is satisfactory enough (Name of school has all  
drinking water facilities for the students and maintenance of staff and sanitation and is monitoring  
the hygiene sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State U. I. Govt.

The above valid for a period of \_\_\_\_\_

Signature with Seal

Name

Designation

[Signature]  
Panchayath Secretary  
Mohammad Ejazuddin  
Panchayath Secretary

To

TSEMRS. Yellareddy petty.  
Rajanna Sircilla-Dist.  
Telangana

(Name & Address of the Institution)

**"ATTESTED"**

[Signature]

**PRINCIPAL**  
**TSEMRS (TSES)**  
Yellareddy petty, Rajanna Sircilla Dist





APPENDIX - III

FORM REGARDING DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE

No. Dum/101/2019

Date: \_\_\_\_\_

It is certified that an inspection was made by Mohammad -  
Ejazuddin Panchayath Secretary (Name of Officer  
with designation) from Panchayath Raj Department (Name of  
Department/Office) inspected the T.T.W.E.M.R.S (Girls) -  
G.P: Dumala Mandli Yellareddy P.O: Rajanna Sircilla Dist. (Address of  
the School) on \_\_\_\_\_ and found that the Sanitation Condition  
and pattern is satisfactory enough (Name of school) and  
drinking water facilities for the students and maintenance of drinking water supply and sanitation  
the existing sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State U.I. Govt.

The above valid for a period of \_\_\_\_\_

Signature with Seal: [Signature]  
Name: Mohammad Ejazuddin  
Designation: Panchayath Secretary

To  
TSEMRS, Yellareddy Peta,  
Rajanna Sircilla Dist.  
Telangana

(Name & Address of the Institution)

**"ATTESTED"**

[Signature]  
**PRINCIPAL**  
**TSEMRS (TSES)**  
Yellareddy Peta, Rajanna Sircilla Dist



**GOVERNMENT OF TELANGANA  
PANCHAYATH RAJ ENGINEERING DEPARTMENT  
INTERNAL WATER QUALITY MONITORING LABORATORY  
RWS&S, SUB-DIVISION - SIRCILLA**

**CHEMICAL & BACTERIOLOGICAL ANALYSIS REPORT OF WATER**



Mandal: Yellareddypet

sample Collected by : FIELD ASSISTANT

Village: Dumala

Date of Collection: 29.01.2019

Location: School

Date of Received: 29.01.2019

Source of water: Bore well water

Date of Report: 29.01.2019

code:

Lab Ref No:

**Chemical Report**

TEST	RESULT	HIGHEST DESIRABLE	MAXIMUM PERMISSIBLE
Value of PH	7.68	7	8.5
Total Dissolved Solids (Mg/L)	1308	500	2000
Alkalinity (Phenolphthelein as CaCo3 (Mg/L)			
[ ] Methyl Orange (Mg/L)	360	200	600
Total Hardness	260	300	600
Chloride (as Cl) (Mg/L)	122	200	1000
Fluoride (as F) (Mg/L)	2.40	1.0	1.5
Nitrate (as No3) (Mg/L)	13.4	45	100
Sulphate (as So4) (Mg/L)	34	200	400
Iron (as Fe) (Mg/L)	0.04	0.3	1.0
<b>REMARKS: Fluoride is high, This source is not fit for drinking purpose</b>			

*[Handwritten Signature]*

**ASSISTANT CHEMIST / MICROBIOLOGIST  
INTERNAL WATER QUALITY MONITORING LABORATORY  
RWS & S , SUB-DIVISION - SIRCILLA**

*|| Attested ||*

*[Handwritten Signature]*

**PRINCIPAL  
TSEMRS (TSES)  
Yellareddypet, Rajanna Sircilla Dist.**